



Addendum No. 8
OSWWTP Phase 1 Replacement Project
Corolla, Currituck County, North Carolina
July 7, 2015

The following shall take precedence over the plans and specifications of the above named project and shall become part of the Contract Documents. Original items of the specifications, contract documents and information indicated on the drawings not herein modified, amended, voided or suspended shall remain in effect.

General

The following are questions posed by plan holders. The questions are in *italicized* text and the answers are in **bold** text.

1. *Is there a fan in the gable or just a louver?*

Please reference plan sheet M1.0 Mechanical New Work Floor Plan. This sheet calls out a louver and back draft damper on the north gable and a louver and sidewall exhaust fan on the south gale end. There is also a louver with gravity backdraft damper on the west wall.

2. *On the attached plan , it stated type 1 FTB but we will need to know the depth needed in order to quote provide a quote?*

According to the bathymetric data a 4 foot turbidity curtain should cover the distance from the normal liquid level to the bottom of the pond in the area proposed to contain the turbidity curtain.