



Eric T. Weatherly, P.E.
County Engineer

Currituck County

153 Courthouse Road, Suite 302
Currituck, North Carolina 27929
252-232-6035

FAX 252-232-3298

Eric.Weatherly@CurrituckCountyNC.gov

ADDENDUM # 1

Project Name: Replace Existing 24" Stormwater Pipe with Alternate Bid for Bridge Option

Location: Currituck County Government Center Complex

Owner: County of Currituck

Date: March 9, 2015

BIDDERS MUST ACKNOWLEDGE RECEIPT OF ADDENDUM #1 ON THE BID FORM.

1. Construction Notes, General, Note 1. :

The contractor may bid each option individually and is not required to submit a bid on all the options.

2. Construction Notes, Replace Existing 24" Stormwater Pipe Option, Note 1. e) :

In lieu of installing the new culvert at the same invert of the existing culvert, the new culvert shall be installed in undisturbed soil approximately 10' south of the existing culvert location. The new culvert shall be installed at an invert elevation of 6.0' (per the existing drawings) or at an invert depth of 4' below the top of existing sidewalk slab. All other notes for removal of existing culvert, materials and backfill requirements shall apply. The contractor may use the existing bid form for this bid price.

3. Construction Notes, Bridge Option, Note 1. a) :

The contractor shall remove the existing culvert prior to construction of the new swale and bridge.