



## **ADDENDUM # 1**

Project Name: Yorktown Water Supply Well No. 1 for the Southern Outer Banks Water Treatment Plant

Location: Currituck County, Corolla, NC

Date: July 29, 2016

**BIDDERS MUST ACKNOWLEDGE THE RECEIPT OF ADDENDUM # 1 ON THE BID FORM.**

The following clarifications/changes are made to the Contract Documents:

1. Specifications - Section 11155 – Submersible Turbine Well Pumps, Part 2.01.B:
  - a. Preapproved submersible well pump substitutions will be allowed.
2. Specifications - Section 11155 – Submersible Turbine Well Pumps, Part 2.04.J:
  - a. Change operating point flow from 450 gpm to 400 gpm. Note the TDH remains unchanged.
  - b. Change riser pipe length from 150 feet to 160 feet.
3. Plans – Drawing M2 – Section A
  - a. Change pump column from 150'-0" to 160'-0".

End of Addendum # 1

Eric T. Weatherly, PE, County Engineer  
County of Currituck, NC