

MEMORANDUM

July 14, 2020

Re:

ADDENDUM NO. 2

TO ALL PROSPECTIVE BIDDERS for the Carova Beach Park Bulkhead Repair for which bids are now to be received by Currituck County.

As follows below with the following revision to specifications and bid documents that are hereby made as part of the Contract Documents and Specifications for the above-mentioned project.

1. Fertilizing and Seeding – Delete “REPAIR AND MAINTENANCE” and “ACCEPTANCE” sections from pages 4 and 5.

2. Revise: Carpentry Specification:

Revise: Lumber to be used for the construction of wooden handrails and decking will be ~~#1 dense/dressed~~ #2 premium/dressed.

Revise: Pressure Treated:

Piles – Round and square piles Rough or Dressed, #2 ~~dense~~

Wales – Rough or Dressed, #2 ~~dense~~

Deadman – Rough or Dressed, #2 ~~dense~~

Joist – Rough or Dressed, #2 ~~dense~~

Decking – Dressed, #2 ~~dense~~ Premium

Handrails – Dressed, #2 ~~dense~~, Premium

Girders – Rough or Dressed, #2 ~~dense~~

3. Revise: Driven Timber Piles/Wales/Deadman Specification:

Wales: Square 6”x6” and 4”x6”, rough or dressed #2 ~~#1~~

Boardwalk Boards - #2 dressed, premium ~~dense rough~~

Joist - #2 rough or dressed ~~dense dressed~~

Handrails - #2 ~~dense~~ dressed, premium

Add: Testing Agency:

Quality Control for test pile operations and test piles shall be performed by an Independent Testing Agency approved by the OWNER or ENGINEER, paid for by the contractor. Quality Control for the remaining piles will be at the discretion of the Engineer and or Testing Agency.

4. Revised Drawing “Site Plan – Sheet 3 of 3”

Delete “Dense” from Typical Section of Bulkhead & Pier Repair Detail for both 4”x4” and 6”x4” wales.

Delete “Dense” from multiple location in “Magnified View”

Revise – Note

Wood Material (Railing and Deck Boards) are to be #2 ~~dense~~premium

5. Revised Bid Form to Add:

“Additive Bid Item 2: Extra 8” Diameter Pile Length due to load test results. There will be a deduct for length not used.

Lump sum \$ _____ for 200 linear feet @ \$ _____ per linear ft

_____ per linear ft

Write out total dollar amount in words

No additional unofficial or inferred information or conversations whatsoever different will be considered part of the contract documents other than those clearly stated on the Construction Drawings and all Items included on Addendum 2. No acknowledgement will be given to either party of any phone call or conversation of any kind regardless of location that has not been objectively discussed by the previous documents of subsequent Addenda.

All bidders shall understand that the Addenda are mandatory part of the Bid Documents, and therefore acknowledge unequivocally their receipt and acceptance of this **Addendum No. 2** by signing in the space provided and submitting the signed Addenda with the Bid. **Failure to include the properly signed Addenda documents will be cause for rejection and dismissal of the bid.**

RECEIPT ACKNOWLEDGED BY:

Principal

Contractor

Date